



**ADDENDUM NUMBER: 1**

**For**

**IFB 742-22-207-1  
STC LAB 2205 FINISH-OUT**

**University of Texas Permian Basin  
4901 E. University Blvd.  
Odessa, TX 79762**

**Questions/Answers**

**Question:**

In regards to the Five Wet Benches 8/A2.1

Is it the intent to match the units already on campus?

I believe the existing units have plastic laminate countertops.

If these benches are "Wet" maybe Epoxy Resin or Phenolic Resin should be utilized.

Does Alternate #2 double these Wet Benches?

I found a picture of one of these from a past project (Attached)

**ANSWER:**

The overall look is to match existing but the actual tops on these units is to be the resin tops. Alternate No. 2 is an extra five (5) benches.

**Extend Bid Date Extended to Tuesday, May 31,2022 10:00 AM (CST)**

**Extend HSP Plan Due: Tuesday, May 31, 2022 2:00 PM (CST)**

***BIDDERS MUST ACKNOWLEDGE RECEIPT OF ADDENDUM(S)***

---

***Elsa Montalvo, Director of Purchasing***

***END OF ADDENDUM***